



DIMENSIONS											FILTERS	
MODEL	A	B	C	D	E	F	H	J	K	L	M	V-BANK
224	55	110	90	10	20	100	116	122	3	35	8	(8) 24x24 (12) 24x25
230	60	145	115	15	25	135	151	157	4	40	5	(8) 24x24 (30) 24x25

NOTES:

- 1.) DRAWING IS NOT TO SCALE. DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTIFICATION.
- 2.) UNIT SHOULD BE INSTALLED A MINIMUM OF 36" FROM GROUND.
- 3.) OUTDOOR UNITS ARE PROVIDED WITH WEATHERPROOF HOUSINGS OVER FAN MOTOR, DRIVES AND DAMPER OPERATOR.
- 4.) ALL UNITS ARE PRE-PIPED, PRE-WIRED, AND FIRE-TESTED PRIOR TO SHIPMENT.
- 5.) INLET SCREEN IS PROVIDED ON OUTDOOR UNITS.
- 6.) MOUNTED TO UNIT BOTTOM. OMITTED WITH UNITS WITH MOUNTING STAND.

K:\SALES LIT\7224230V

Installation Code and Annual Inspections:

All installations and service of WEATHER-RITE™ products must be performed by a contractor qualified in the installation and service of products sold and supplied by Weather-Rite, LLC and conform to all requirements set forth in the WEATHER-RITE™ manuals and all applicable governmental authorities pertaining to the installation, service and operation of the equipment. To help facilitate optimum performance and safety, Weather-Rite, LLC recommends that a qualified contractor annually inspect your WEATHER-RITE™ products and perform service where necessary, using only replacement parts sold and supplied Weather-Rite, LLC.

This document is intended to assist licensed professionals in the exercise of their professional judgement.