



MODEL	DIMENSIONS			FILTERS
	A	B	C	V-BANK
233	160	10	17	(56) 2d2b20
236	180	25	22	(84) 2d2b20

**NOTES:**

- 1.) DRAWING IS NOT TO SCALE. DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTIFICATION.
- 2.) HH AND HB ARRANGEMENTS ARE STANDARD. CONSULT FACTORY FOR OTHER ARRANGEMENTS.
- 3.) UNITS SHOULD BE INSTALLED AT MINIMUM 24" FROM GROUND.
- 4.) OUTDOOR UNITS ARE PROVIDED WITH WEATHERPROOF HOUSINGS OVER FAN MOTOR, DRIVES AND DAMPER OPERATOR.
- 5.) HB UNITS MAY CARRY OVER MOISTURE, DO NOT INSTALL OVER DAMAGEABLE MATERIALS.
- 6.) INLET SCREEN IS PROVIDED ON OUTDOOR UNITS.
- 7.) ALL UNITS ARE PRE-PIPED, PRE-WIRED, AND FIRE TESTED PRIOR TO SHIPMENT.

K:\SALES LIT\1233236H

**Installation Code and Annual Inspections:**

All installations and service of WEATHER-RITE™ products must be performed by a contractor qualified in the installation and service of products sold and supplied by Weather-Rite, LLC and conform to all requirements set forth in the WEATHER-RITE™ manuals and all applicable governmental authorities pertaining to the installation, service and operation of the equipment. To help facilitate optimum performance and safety, Weather-Rite, LLC recommends that a qualified contractor annually inspect your WEATHER-RITE™ products and perform service where necessary, using only replacement parts sold and supplied Weather-Rite, LLC.

This document is intended to assist licensed professionals in the exercise of their professional judgement.