



MODEL	DIMENSIONS															FILTERS		
	A	B	C	D	E	F	G	H	I	J	K	L	M	N	P	Q	V-BANK (#) & SIZE	HOOD (#) & SIZE
112	48	24	58	15	27	19.5	26	13.44	5	7	1	28	36	15.62	-	26	(3) 2x20x20	(2) 2x20x25
115	48	24	58	15	27	19.5	26	15.88	5	8.25	3.75	28	36	18.62	-	26	(3) 2x20x20	(2) 2x20x25
212	48	24	58	15	27	19.5	50	13.44	5	7	1	28	60	15.62	11	50	(8) 2x20x20	(8) 2x20x25
215	48	28	58	15	27	19.5	50	15.88	5	8.25	3.75	28	72	18.62	11	58	(4) 2x20x20	(4) 2x20x25
218	72	24	62	15	33	26	58	18.88	6	10.5	10.5	36	72	21.88	14.25	58	(8) 2x20x20	(8) 2x20x25
221	72	26	72	20	38	33	76	24.75	6	11.25	4.75	42	100	22.75	23.5	80	(16) 2x20x20	(15) 2x20x25

**NOTES:**

- 1.) DRAWING IS NOT TO SCALE. DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTIFICATION.
- 2.) UNITS ONLY SUPPLIED IN LEFT HAND ARRANGEMENT AS SHOWN.
- 3.) STANDARD ADJUSTABLE DRIVE THROUGH 10 HP.
- 4.) OUTDOOR UNITS ARE PROVIDED WITH WEATHERPROOF HOUSINGS OVER FAN MOTOR, DRIVES AND DAMPER OPERATOR.
- 5.) HB UNITS MAY CARRY OVER MOISTURE, DO NOT INSTALL OVER DAMAGEABLE MATERIALS.
- 6.) UNIT SHOULD BE INSTALLED A MINIMUM OF 24 INCHES FROM ROOF.
- 7.) ALL UNITS ARE PRE-PIPED, PRE-WIRED, AND FIRE-TESTED PRIOR TO SHIPMENT.

K:\SALES LIT\101-HORZ

**Installation Code and Annual Inspections:**

All installations and service of WEATHER-RITE™ products must be preformed by a contractor qualified in the installation and service of products sold and supplied by Weather-Rite, LLC and conform to all requirements set forth in the WEATHER-RITE™ manuals and all applicable governmental authorities pertaining to the installation, service and operation of the equipment. To help facilitate optimum performance and safety, Weather-Rite, LLC recommends that a qualified contractor annually inspect your WEATHER-RITE™ products and perform service where necessary, using only replacement parts sold and supplied Weather-Rite, LLC.

This document is intended to assist licensed professionals in the exercise of their professional judgement.